



Government Of West Bengal
Office Of The Divisional Fire Officer, Paschim Medinipur
West Bengal Fire & Emergency Services
Sepoy Bazar, P.O.:- Medinipur, P.S.:- Kotwali, Pin:- 721101

Memo no.:FSR/0125186231400319

Date: 05-12-2023

From:
Divisional Fire Officer, Paschim Medinipur
West Bengal Fire & Emergency Services

To: PURBA MEDINIPUR B. ED COLLEGE
PLOT NO - 168,776,777, JL NO - 64, MOUZA - CHAITANYAPUR, P.S. - SUTAHATA, DIST. - PURBA MEDINIPUR, PIN - 721645(W.B.)

Sub: Issuance of Fire safety Certificate in favor of An existing Educational Establishment consisting of 3 nos. block as Phase -I, G+III storied, Phase - 2, G+II storied, Phase -3, G+II storied college building, Namly - "Purba Medinipur B.ED College", under Group - Educational, Address - Mouza-Chaitanyapur, Plot No. - 776, 777, 168, J.L. No. - 64, P.S. - Sutahata, Dist - Purba Medinipur, PIN - 721645.

This is in reference to your application no. 0125189231400190 dated 01-11-2023 regarding the Issuance of Fire safety Certificate in favor of An existing Educational Establishment consisting of 3 nos. block as Phase -I, G+III storied, Phase - 2, G+II storied, Phase -3, G+II storied college building, Namly - "Purba Medinipur B.ED College", under Group - Educational, Address - Mouza-Chaitanyapur, Plot No. - 776, 777, 168, J.L. No. - 64, P.S. - Sutahata, Dist - Purba Medinipur, PIN - 721645.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

- 1)Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No Parking will be allowed on the Driveway.
- 2)One standby pump of 900 LPM shall be installed and connected with the existing pump with auto starting facility.
- 3)One separate down comer with hose reel hose shall be installed in another stair to cover whole building
- 4)Sprinkler shall be installed in multipurpose hall, library room etc.
- 5)All obstructions in corridor shall be cleared.

- 6)LPG Gas bank shall be made outside the Kitchen as per IS specifications and kitchen shall be protected with CO2 extinguisher. Kitchen shall be constructed outside the college building.
- 7)Exit ways shall be marked properly and all exit ways shall remain open during working hours.
- 8)The Interior finish decoration of building shall be made with low flame spread material conforming to the IS Specification.
- 9)To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
- 10)Electrical wiring of the whole building shall have to be carefully checked for any where any tear in them, particularly lines having false ceiling and ducts,
- 11)The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable of the building.
- 12)The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.
- 13)Mock Fire Practice and evacuation drill shall be performed periodically with Participants of all the occupants of the building.
- 14)Meter room shall be protected with Co2 Fire Extinguisher conforming IS specification,
- 15)First-Aid Fire Fighting system shall be provided as per I.S specification.
- 16)Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the building to keep them in perfectly good working condition at all the times.
- 17)Periodical flashing of water in the Hose Reel Hose line / hydrant Valve shall be made to maintain the efficiency working performance of above mention system.
- 18)If required the old lines shall have to be replace with new lines cables shall always be laid in M.S. conduct pipes continuously bounded to the earth,
- 19)The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
- 20)Revised Fire Safety Recommendation shall be applied for any addition & alternation made in the structure.
- 21)This Fire Safety Certificate is valid for three years and has to be renewed in every three years from the date of issue of this letter Vide Notification No.- 629_L dated 17.04.2018 and Memo No.- WBFES/604(200)/2919 dated 01.02.2019.
- 22)The Renewal Fire Safety Certificate is to be obtained from the Director General, West Bengal Fire and Emergency Services performance of all the life and Fire Safety arrangements and installations of the building.

Signature Not Verified
Digitally Signed.
Name: Bam Kumar Chowdhury
Date: 05-Dec-2023 09:41:13
Reason: Approved
Location: West Bengal

Member Convener Kharagpur TEC, Paschim
Medinipur
West Bengal Fire & Emergency Services

Memo No.:FSR/0125186231400319